



FORT MYERS BEACH FIRE CONTROL DISTRICT

Life Safety Branch

100 Voorhis Street
Fort Myers Beach, Florida 33931
Office: 239-590-4210
Email: prevention@fmbfirefl.gov
Website: www.fmbfirefl.gov

Occupant Name:	CRECIENTE CONDOMINIUMS EAST	Inspection Date:	2/12/2026 (Initial Insp. Date: 11/17/2025)
Address:	7148 ESTERO Boulevard	InspectionType:	Reinspection #1 (Apartment or Condominium)
City:	FT MYERS BEACH	Inspected By:	William Genevrino 239-898-5154

Insp. Result	Location	Code Set	Code
Fail - Cleared	Floor 1	FL NFPA 01 2021 Chapter 1 Administration	1.17* - Permit Fees.
	✓ Cleared on 2/12/2026		
Fail - Cleared	Floor 5	FL NFPA 01 2021 Chapter 14 Means of Egress	14.13.1.3 - EMERGENCY LIGHTS: CHANGE OF POWER
	✓ Cleared on 2/12/2026		
Fail - Cleared	Floor 8 Trash chute room	FL NFPA 01 2021 Chapter 12 Features of Fire Protection	12.7.8.1.1 - Excerpt: [The provisions of 12.7.8 shall govern the mater...]
	✓ Cleared on 2/12/2026		
Fail - Cleared	Floor 9 Roof top	FL NFPA 01 2021 Chapter 11 Building Services	11.1.2.1 - ELECTRICAL: INSTALLATION AND MAINTENANCE
	✓ Cleared on 2/12/2026		
Fail - Cleared	Floor 9 West stairwell	FL NFPA 01 2021 Chapter 13 Fire Protection Systems	13.1.2 - FIRE SYSTEMS: TESTING AND MAINTENANCE
	✓ Cleared on 2/12/2026		

Notice of Violation

YOU ARE HEREBY NOTIFIED, that a Fire and Life Safety Inspection was performed today by a Fort Myers Beach Fire Control District Life Safety Specialist named above, for the purposes of ensuring compliance with *Florida Statute Chapter 633, Florida Fire Prevention Code, and Florida Administrative Code 69A*. The results of this inspection indicated that a violation(s) of cited Statute or Codes exist at this time. You are further notified that this notice serves as your official **Notice of Violation** in compliance with *Florida Statute Chapter 162 and Florida Statute Chapter 633*.

YOU ARE HEREBY DIRECTED, to abate or remedy the above noted violation(s) within (45) days of the receipt of this notice. At the discretion of the Fire Official, a reasonable time extension and/or alternatives may

