



FORT MYERS BEACH FIRE CONTROL DISTRICT

Life Safety Branch

100 Voorhis Street
 Fort Myers Beach, Florida 33931
 Office: 239-590-4210
 Email: prevention@fmbfirefl.gov
 Website: www.fmbfirefl.gov

Occupant Name:	CRECIENTE CONDOMINIUMS SOUTH	Inspection Date:	2/12/2026 (Initial Insp. Date: 11/17/2025)
Address:	7150 ESTERO Boulevard	InspectionType:	Reinspection #1 (Apartment or Condominium)
City:	FT MYERS BEACH	Inspected By:	William Genevrino 239-898-5154

Insp. Result	Location	Code Set	Code
Fail - Cleared	Floor 1 Cleared on 2/12/2026	FL NFPA 01 2021 Chapter 1 Administration	1.17* - Permit Fees.
Fail - Cleared	Floor 1 Storage room 1 Cleared on 2/12/2026	FL NFPA 01 2021 Chapter 11 Building Services	11.1.2.1 - ELECTRICAL: INSTALLATION AND MAINTENANCE
Fail - Cleared	Floor 1 Trash collection room Cleared on 2/12/2026	FL NFPA 01 2021 Chapter 12 Features of Fire Protection	12.7.8.1.1 - Excerpt: [The provisions of 12.7.8 shall govern the mater...]
Fail - Cleared	Floor 2 South stairs Cleared on 2/12/2026	FL NFPA 01 2021 Chapter 14 Means of Egress	14.13.1.3 - EMERGENCY LIGHTS: CHANGE OF POWER
Fail - Cleared	Floor 2 Trash room Cleared on 2/12/2026	FL NFPA 01 2021 Chapter 12 Features of Fire Protection	12.7.8.1.1 - Excerpt: [The provisions of 12.7.8 shall govern the mater...]
Fail - Cleared	Floor 3 South stairs Cleared on 2/12/2026	FL NFPA 01 2021 Chapter 13 Fire Protection Systems	13.1.2 - FIRE SYSTEMS: TESTING AND MAINTENANCE
Fail - Cleared	Floor 3 Trash room Cleared on 2/12/2026	FL NFPA 01 2021 Chapter 12 Features of Fire Protection	12.7.8.1.1 - Excerpt: [The provisions of 12.7.8 shall govern the mater...]
Fail - Cleared	Floor 4 4TH FLOOR TRASH CHUTE ROOM Cleared on 2/12/2026	FL NFPA 01 2021 Chapter 12 Features of Fire Protection	12.7.8.1.1 - Excerpt: [The provisions of 12.7.8 shall govern the mater...]

